

**FISHER-ROSEMOUNT™**

**Customer Guide  
For  
Boiler Control Package**

---

# Introducing the Boiler Control Package

## What's a Boiler Control Package (BCP)?

Boiler Control Package provides a pre-engineered control strategy for gas-fired (and optionally gas or oil-fired) boilers. These controls comply with NFPA 85: Boiler and Combustion Systems Hazards Code. They include feedwater and 3-element drum level, plus combustion controls with boiler master, parallel metered air and fuel, with oxygen trim. Steam header pressure control for two boilers is standard with the package.

BCP is designed for application by those experienced with boilers and DeltaV hardware and software configuration. This package addresses small-, medium-, and larger-sized boiler applications. In addition, we can customize the package specific to your boiler. BCP has been used successfully in more than 100 installations including those firing single fuels, gas or oil fuel, multiple fuels, waste fuels, stoker fired boilers, and with steam capacities ranging from 15 to 400 KPPH.

## Why improve boiler controls?

Reasons include: Automating a new installation where reliable boiler controls is essential, retrofitting existing units to eliminate upsets that impact plant operations, or for reduced fuel cost by improving boiler efficiency. On gas-fired boilers, a 1% fuel savings with fuel cost of \$7/therm could save \$70k/year. Larger boilers favor even greater economic savings. Boilers currently using jackshafts or parallel-positioning controls will offer significant fuel savings while increasing reliability.

Since boilers are a key element to keeping any operation running smoothly, customers need a reliable, efficient, and well-engineered solution.

## Why use pre-configured software?

Because it includes the best that experience can provide about control techniques, BCP saves a lot on engineering and provides significant economic advantage. Cost is usually half that required for a custom solution, even when using an integrator who's knowledgeable in boiler control and experienced with the control system. Customers with multiple sites prefer to standardize their boiler control systems to avoid the mistakes and inconsistencies in design and implementation that often arise when using different personnel from different companies.

Configuration software and documentation is delivered via e-mail. One electronic copy of documentation in PDF format is provided that includes design and recommended tuning information.

## Boiler Control Package Customer Guide

---

### What controls are provided?

A plant steam header pressure loop provides adaptive gain for one or two boiler units. Load changes are rate-limited to allow feedwater systems to keep up with firing rates. Systems with only one standalone boiler or for those with more than two boilers are optional – minor changes are required in those cases.

- | A boiler master loop is dedicated to each boiler for regulating air and fuel flow control and provides individual unit load biasing. Transfers to the plant master for firing rate are bumpless and use ramping for smooth transitions to and from base loaded operation.
- | Air and fuel gas controls use parallel metering and cross-limiting with airflow. Cross-limiting means coordinated flow of fuel and air; i.e. as demand increases, air flow increases before the fuel does, and as demand decreases, fuel flow decreases before airflow. This allows combustion to be more efficient while preventing O<sub>2</sub> from going too low. Fuel flow includes a low limit when in automatic mode, with manual control allowed over the full range. The base package is designed for use with single gas fuel, or for gas or oil firing (not-simultaneously).
- | Airflow is characterized to match fuel flow and burner geometry. Because fuel is balanced with air flow at all loads, this enhances the performance of the unit over those strategies based simply on fuel BTU.
- | Excess air trim is provided with stack oxygen and is adapted with fuel flow. The operator is allowed to bias fuel-to-air ratios within normal operating limits. For multiple fuels, the setpoint is adapted both with fuel type and load.
- | Drum level controls provide for 1- or 3-element operation. 1-element is automatically selected at low steam loads, when signals from field devices are bad, or whenever the operator wants to override. Selection of 3-element mode is either automatic (based on steam load) or can be held in 1-element mode by the operator. 3-element mode uses a cascade arrangement of level to feedwater flow with steam flow as a feedforward. If feedwater flow is not metered, an optional 2-element drum level control strategy is available.
- | Mode transfers are bumpless and balanceless.
- | To reduce hazards, all analog inputs used with control are monitored to detect bad status. When bad status is detected, the loop is automatically changed manual mode and alarmed to assure the operator is aware of any problems.
- | To help prevent errors, fuel flow, airflow, and boiler master modes are interlocked to provide correct hierarchy during changes, or equipment failures.
- | Standard displays include one typical for boiler details plus for one boiler plant overview or for use with maintaining steam header.

## Boiler Control Package Customer Guide

| Simulation of BCP is included for use in implementation: The simulation uses DeltaV logic that is separate and removed prior to operation.

### What's not included?

Services are required to modify database or displays, plus startup support. Database is modified with specific tag names, descriptions, engineering units and ranges, words and limits used for alarms, and merging within the existing system. Additional services may also be required for functional modifications, additional controls, or monitor-only data.

### Does the package provide burner management?

No. Burner Management System (BMS) functions are separate from boiler controls. Clients may retain their existing BMS or choose to modernize with a BMS based on DeltaV, PLC, or dedicated microprocessor.

Usually boiler controls are interfaced to the BMS for purge or light off. The advantages are faster lightoffs and fewer delays in getting the boiler operating. Options are available for single-burner gas fuel, or for gas or oil firing. When the BMS interface is requested, the minimum requirement with only one fuel is two discrete inputs. For gas or oil firing, five discrettes are required. A detailed description will be provided with a proposal.

### What documentation is provided?

The manual for Boiler Control Package is clearly and extensively documented. Configuration software is modular with thorough comments to clearly indicate purpose and activities. Manuals are provided only with purchase of a license and are supplied in PDF format.

### What options are available?

We realize all boilers are not alike. To help meet individual customer needs, a number of options are available and additionally, we can support a wide variety of custom modifications like the following:

<b>Questions to Consider</b>	<b>Options</b>
<i>Who can provide the technical services for modifying the database, displays, or merging with the existing database?</i>	Technical services are available locally from local FR representatives to customize tags, descriptors, I/O configuration to reflect plant-naming conventions, and custom hardware layout.
<i>How many boilers does the steam header pressure loop control?</i>	The standard package controls two boilers. Options are available for controlling only one boiler or for more than two boilers.

## Boiler Control Package Customer Guide

<p><i>How many fuels and type are fired?</i></p>	<p>The standard package has two versions: one for a single fuel, and the other for gas or oil firing (not simultaneously). An interface with Burner Management System is available for use with single fuel or gas or oil firing is included.</p> <p>Combination firing with waste fuels is commonly done. Let us know if there are other fuels or differences and we can provide optional services to match the boiler.</p>
<p><i>Are any transmitters required to be redundant?</i></p>	<p>No. However, for boilers requiring high availability, this option is sometimes considered for steam header pressure, drum level, or oxygen.</p>
<p><i>Do the air fans use variable speed drive? Is a damper used in combination with VSD?</i></p>	<p>A variable speed drive may be used directly. However, where a damper is also used in combination with speed control additional services may be required.</p>
<p><i>Is furnace pressure controlled? If so, are there multiple pressure transmitters?</i></p>	<p>A furnace pressure control option is available for induced draft (ID) fans. For large units, three transmitters may be required to comply with NFPA.</p>
<p><i>How many elements are used for level control?</i></p>	<p>If feedwater flow is measured, 3-element control is used. If feedwater flow is not measured, then a drum level logic option is available for 2-element control (level and steam flow).</p>
<p><i>What if we have two or more burners?</i></p>	<p>If one fuel valve serves all burners, BCP requires no changes.</p>

## Boiler Control Package Customer Guide

<i>Is operator training available?</i>	Operators are trained using the simulator included with BCP. This allows operators and engineers to experiment with both normal and abnormal conditions that affect unit operation. The training simulator is also useful for testing and verifying that the control strategy performs the correct actions.
<i>Can fuel oil pressure be controlled with DCS?</i>	This can be done as an option: however, this is usually done using a back-pressure regulator.

### What about hardware architecture and function location?

High reliability is achieved with a simplex controller and I/O cards dedicated to each boiler. This allows each unit to be down separately and without impact on other parts of utility plants. Redundant controllers or I/O may be used for higher reliability, or where common utility items are required such as plant header pressure controls, deaerator, feedwater pumps, or water treatment.

Burner Management System (BMS) inputs should always be hardwired to the controller. A serial input card can communicate BMS monitor inputs, which are not control-related.

### Is there a software warranty?

Warranty on BCP licensed software is provided for 90 days after shipment and covers defects in workmanship and design. Any changes made in functionality not provided by factory or resulting from miss-use are not warranted and the customer may incur cost for assistance. During the warranty period, notification of possible problems and corrections are provided.

### Need more than just controls?

Emerson Process Management offers virtually all the process controls hardware, software, and services a user may need. Here's what can be provided:

- | ASCO valves and switches <http://www.ascovalve.com/>
- | Boiler Control Package <http://www.easydeltav.com/solutions/boiler.asp>
- | Valves, positioners, and damper drives <http://www.emersonprocess.com/fisher/>
- | On-off valves <http://www.emersonprocess.com/valveautomation/>
- | Regulators for gas fuel regulation and steam atomization <http://www.fisherregulators.com/>
- | Smart transmitters <http://www.rosemount.com/>
- | O2 and combustible analyzers <http://www.emersonprocess.com/raihome/>
- | Continuous Emissions Monitoring <http://www.emersonprocess.com/proanalytic/>

## Boiler Control Package Customer Guide

- | Mass flow meters <http://www.emersonprocess.com/micromotion/>
- | Brooks flowmeters and totalizers <http://www.emersonprocess.com/brooks/>
- | UPS systems <http://www.liebert.com/>
- | Electrical Motors <http://www.usmotors.com/>
- | Variable speed drives <http://www.controltechniques.com/>
- | Valve services <http://www.emersonprocess.com/fisher//>
- | Educational Services <http://www.easydeltav.com/solutions/train/index.asp>
- | Boiler commissioning services <http://www.control-dynamics.com/>
- | DeltaV based Burner Management Systems <http://www.control-dynamics.com/>
- | DeltaV control systems <http://www.emersonprocess.com/systems/>

### How about technical or pre-project Engineering assistance?

For clients who are interested in improving their boiler controls but are lacking in expertise to either determine their specific needs, consider using one of our boiler experts to conduct an on-site study. These studies vary in both depth and scope. Many just require a one-day visit with a follow-up report that explains what was observed and how controls can improve your boiler operations. More in-depth studies will involve economic justification and may take longer to complete.

### I/O Requirements

The following I/O is a minimum for control. For secure architecture, I/O is broken out by controller for each boiler. Additional I/O may be desired for monitoring or controls for deaerator, feedwater treatment, boiler blowdown, etc.

#### Typical I/O for steam header controls:

I/O Expected	Area	AI 4-20 mA	AO 4-20 mA	DI dry contact	DO dry contact
steam header pressure	common	1			

#### Typical I/O for one gas fired boiler:

I/O Expected	Area	AI 4-20 mA	AO 4-20 mA	DI dry contact	DO dry contact
steam flow	Boiler	1			
drum level	Boiler	1			
drum pressure	Boiler	1			
boiler feed water flow	Boiler	1	1		
combustion air flow	Boiler	1	1		
fuel gas flow	Boiler	1	1		
fuel gas pressure <sup>1</sup>	Boiler	1			
stack oxygen	Boiler	1			
purge status <sup>2</sup>	Boiler			1	
lowfire status <sup>2</sup>	Boiler			1	

## Boiler Control Package Customer Guide

release to mod status <sup>2</sup>	Boiler			1	
<b>TOTAL</b>	<b>TOTAL</b>	<b>8</b>	<b>3</b>	<b>3</b>	<b>0</b>

### Typical I/O for one gas or oil dual fired boiler:

I/O Expected	Area	AI 4-20 mA	AO 4-20 mA	DI dry contact	DO dry contact
steam flow	Boiler	1			
drum level	Boiler	1			
drum pressure	Boiler	1			
boiler feed water flow	Boiler	1	1		
combustion air flow	Boiler	1	1		
fuel gas flow	Boiler	1	1		
fuel gas pressure <sup>1</sup>	Boiler	1			
fuel oil flow	Boiler	1	1		
stack oxygen	Boiler	1			
purge status <sup>2</sup>	Boiler			1	
lowfire status <sup>2</sup>	Boiler			1	
release to modulate <sup>3</sup>	Boiler			1	
gas fuel selected status <sup>3</sup>	Boiler			1	
oil fuel selected status <sup>3</sup>	Boiler			1	
fuel transfer status <sup>3</sup>	Boiler			1	
<b>TOTAL</b>	<b>TOTAL</b>	<b>9</b>	<b>4</b>	<b>6</b>	<b>0</b>

#### I/O Notes:

- 1 - optional input for monitoring or pressure-temperature compensation
- 2 - inputs for burner management interface
- 3 - additional inputs required for gas or oil firing

*DeltaV is a mark of one of the Fisher-Rosemount group of companies. All other marks are the property of their respective owners.*

*The contents of this publication are presented for informational purposes only, and while every effort has been made to ensure their accuracy, they are not to be construed as warranties or guarantees, express or implied, regarding the products or services described herein or their use or applicability. We reserve the right to modify or improve the designs or specifications of such products at any time without notice*

## Boiler Control Package Customer Guide

*Control Dynamics, based in Midlothian, VA, is a certified FR provider of boiler control services including consulting, studies for project justification, and commissioning services.*